

MEMORANDUM

TO: North Castle Planning Board

CC: North Castle Conservation Board
Adam Kaufman, AICP
Michael Campbell, P.E.
Wallace Toscano, AIA
Greg & Elisa Weinhoff

FROM: John Kellard, P.E. *JK*
Kellard Sessions Consulting
Consulting Town Engineers

DATE: February 9, 2023

RE: Greg & Elissa Weinhoff
3 Maple Way
Section 101.04, Block 2, Lot 74

As requested, Kellard Sessions Consulting has reviewed the site plans and application submitted in conjunction with the above-referenced project. The applicant is proposing to demolish the existing residence and construct a new residence with garage, new inground pool, pool house, pool deck, new asphalt driveway with turnaround and a new septic system. The property is 1.8 acres in size and located within the Single-Family Residential R-1A Zoning District.

The project site includes Paxton Upland Soils within the rear yard in the vicinity of the proposed septic system. The remainder of the project site includes hydric Ridgeberry and Sun Soils. A stormwater culvert across the front yard appears to have included the piping of a watercourse. Piping was likely installed when the original home was constructed.

Our comments are outlined below.

GENERAL COMMENTS

1. All proposed improvements are located within an area of hydric soils which may have been previously filled. Since hydric soils are defined as wetlands within the Town Wetland Ordinance, the applicant retained Evans Associates Environmental Consulting, Inc., to prepare a Wetland Evaluation Report. The report should be reviewed by the Town Wetland Consultant.

2. The project will disturb one (1) acre which will require a Stormwater Pollution Prevention Plan (SWPPP) which addresses erosion and sediment controls, water quality and water quantity mitigation for all storms through the 100-year storm event. The SWPPP must conform with the New York State Department of Environmental Conservation (NYSDEC) General Permit GP-0-20-001. A Notice of Intent (NOI) and SWPPP MS4 Acceptance Form will need to be filed with the NYSDEC. The SWPPP should be submitted to our office for review.
3. The plan should include drainage collection and piping improvements with rim and invert elevations.
4. The applicant shall verify and include within the drainage plan the pipe sizes, invert elevations and slopes of existing drainage improvements carrying the former watercourse through the project site. An evaluation of the existing culvert condition should be provided. The applicant should explain the different pipes and different drainage easements within the front yard. Modification of the drainage easements may be required.
5. The applicant should prepare a grading plan for the project. The proposed septic plan shows regrading which directs site runoff to neighboring properties. Discharge onto adjacent properties should be avoided.
6. The applicant should prepare an erosion and sediment control plan with all mitigation proposed for the project. The plan should include maintenance and inspection requirements during construction, as well as construction details.
7. The applicant should prepare a Construction Detail Sheet, which includes details of all improvements.
8. The applicant should prepare an Existing Conditions Plan showing the existing residence, driveway, septic, etc., to be removed.
9. The applicant should detail the Belgium block pavement at the driveway entrance. A minimum five (5) foot asphalt apron is required before the start of pavers. A Town Highway Department Curb Cut Permit is required and a Road Opening Permit may be required for any utility installations within the Town Right-of-Way.
10. Please confirm by turning template that there is sufficient radii to accommodate vehicles within the front circle.
11. The applicant should show proposed utility connections.

North Castle Planning Board
Weinhoff – 3 Maple Way
February 9, 2023
Page 3 of 3

12. The applicant should show the pool equipment pad and means of discharging pool drawdown volume. Please address discharge mitigation.
13. The basement elevation of 612 is eight (8) feet below the existing grade and therefore, may be within the groundwater table. Please show means of maintaining a dry basement (footing drains, sump pump, etc.) and location of discharge.
14. The applicant is before the Westchester County Department of Health (WCHD) for approval of new septic system to service the proposed residence and pool house. Please submit a copy of approval upon receipt.

As additional information becomes available, we will continue our review. We note that additional information provided to address the above may result in further comment. It is noted that an itemized response to all comments will facilitate completeness and efficiency of review.

PLAN REVIEWED, PREPARED BY CAMPBELL ENGINEERING, DATED DECEMBER 16, 2022:

- Proposed Septic Plan (S1/27)

PLAN REVIEWED, PREPARED BY DANIEL SHERMAN LANDSCAPE ARCHITECT, DATED DECEMBER 14, 2022:

- Site Planting Plan (L-1)

JK/dc