



TOWN OF NORTH CASTLE

WESTCHESTER COUNTY
17 Bedford Road
Armonk, New York 10504-1898

RESIDENTIAL PROJECT
REVIEW COMMITTEE
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625
Fax: (914) 273-3554
www.northcastleny.com

RPRC DETERMINATION LETTER

Project Description: New deck, remove old deck on first floor.

Street Location: 17 GREENBRIAR CIR

Zoning District: R-MF Tax ID: 107.16-3-48 Application No.: 2021-0216

RPRC DECISION: RPRC - Requires Admin Wetlands Permit

Date: 04/06/2021

The above referenced application was reviewed by the Residential Project Review Committee (RPRC).

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The plan shall illustrate and quantify the limits of disturbance. The plan shall note that disturbance limits shall be staked in the field prior to construction.
- Include erosion control measures on the plan, including, but not limited to, temporary construction access, silt fence, stockpile, construction sequence, etc. Provide details.
- The site plan shall contain a note indicating that no trees are proposed to be removed.
- It appears the plan proposes disturbances within the locally-regulated 100-foot wetland buffer from an offsite watercourse. A local administrative Wetland Permit may be required. The applicant shall illustrate the local wetland boundary and regulated 100-foot buffer on the plan for verification by the Town Wetland Consultant. Notify the Town Engineer once the wetland boundary has been established in the field.

At this time, you must submit two hard copies of revised plans addressing the above issues, this determination letter and a completed building permit application directly to the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.