



TOWN OF NORTH CASTLE

WESTCHESTER COUNTY
17 Bedford Road
Armonk, New York 10504-1898

RESIDENTIAL PROJECT
REVIEW COMMITTEE
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625
Fax: (914) 273-3554
www.northcastleny.com

RPRC DETERMINATION LETTER

Project Description: 22 kw generator

Street Location: 6 TRUDY LN

Zoning District: R-2A Tax ID: 102.03-1-29 Application No.: 2021-0955

RPRC DECISION: RPRC - Requires Admin Wetlands Permit

Date: 11/16/2021

The above referenced application was reviewed by the Residential Project Review Committee (RPRC).

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The generator and tank shall be suitably screened to the satisfaction of the Building Department.
- The generator and tank should depict the distance from the structure to adjacent property lines to the satisfaction of the Building Department.
- Given the limited impact of the proposed generator and tank installation, the wetlands permit shall be processed via Building Department administrative wetlands permit.

At this time, you must submit two hard copies of revised plans addressing the above issues, this determination letter and a completed building permit application directly to the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.

Adam R. Kaufman, AICP
Director of Planning