



# TOWN OF NORTH CASTLE

WESTCHESTER COUNTY  
17 Bedford Road  
Armonk, New York 10504-1898

RESIDENTIAL PROJECT  
REVIEW COMMITTEE  
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625  
Fax: (914) 273-3554  
www.northcastleny.com

## RPRC DETERMINATION LETTER

Project Description: Addition, portico, deck  
Street Location: 5 HIDDEN OAK RD  
Zoning District: R-2A Tax ID: 107.01-1-45 Application No.: 2022-0610  
RPRC DECISION: RPRC - Submit to Building Department  
Date: 08/02/2022

---

The above referenced application was reviewed by the Residential Project Review Committee (RPRC).

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The GLC Worksheet (7,872 sf) and the backup data (8,289 sf) do not equate. The worksheet and backup should agree. The Applicant should coordinate the worksheet and backup data.
- The GFA Worksheet (3,890 sf) and the backup data (4,468 sf) do not equate. The worksheet and backup should agree. The Applicant should coordinate the worksheet and backup data.
- The submitted elevations should depict proposed Building Height (average grade to roof midpoint) and Maximum Exterior Wall Height (lowest grade to roof midpoint) for the proposed additions/modifications.
- The applicant shall perform deep and percolation soil testing in the vicinity of the proposed mitigation system to be witnessed by the Town Engineer. The test locations and results shall be shown on the plan. Contact the Town Engineer to schedule the testing.
- The plan shall illustrate the roof drain and drainage pipe connections on the site plan. Include the size, slope and material.

**At this time, you must submit two hard copies of revised plans addressing the above issues, this determination letter and a completed building permit application directly to the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.**

**If blasting or rock chipping is proposed, a permit pursuant to Chapter 122 is required.**

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.