



TOWN OF NORTH CASTLE

WESTCHESTER COUNTY
17 Bedford Road
Armonk, New York 10504-1898

RESIDENTIAL PROJECT
REVIEW COMMITTEE
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625
Fax: (914) 273-3554
www.northcastleny.com

RPRC DETERMINATION LETTER

Project Description: Patio

Street Location: 5 SHIPPEN RD

Zoning District: R-1.5A Tax ID: 107.04-2-51 Application No.: 2022-0602

RPRC DECISION: RPRC - Submit to Building Department

Date: 10/04/2022

The above referenced application was reviewed by the Residential Project Review Committee (RPRC).

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The applicant shall perform deep and percolation soil testing in the vicinity of the proposed mitigation system to be witnessed by the Town Engineer. The test locations and results shall be shown on the plan. Contact this office to schedule the testing.

Provide stormwater mitigation and design calculations for the runoff generated by the net increase in impervious surface for the 25-year, 24-hour design storm event. Provide details of the stormwater mitigation system.

- The applicant has provided storage for 600 s.f. of new impervious surface, however, the land coverage worksheet includes 1,225 s.f. of new impervious surface. Please explain.

At this time, you must submit two hard copies of revised plans addressing the above issues, this determination letter and a completed building permit application directly to the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If blasting or rock chipping is proposed, a permit pursuant to Chapter 122 is required.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.