



TOWN OF NORTH CASTLE

WESTCHESTER COUNTY
17 Bedford Road
Armonk, New York 10504-1898

RESIDENTIAL PROJECT
REVIEW COMMITTEE
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625
Fax: (914) 273-3554
www.northcastleny.com

RPRC DETERMINATION LETTER

Project Description: Patio and addition
Street Location: 65 ROUND HILL RD
Zoning District: R-2A Tax ID: 102.03-1-45 Application No.: 2022-1094
RPRC DECISION: RPRC - Submit to Building Department
Date: 01/10/2023

The above referenced application was reviewed by the Residential Project Review Committee (RPRC).

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The plan shall illustrate existing topography and any proposed grading including spot grades as appropriate.
- The plan shall include driveway dimensions, as appropriate, for the proposed driveway expansion.
- Provide construction details for all proposed improvements, including, but not limited to, driveway, drainage, curbing, etc.
- Provide stormwater mitigation and design calculations for the runoff generated by the net increase in impervious surface for the 25-year, 24-hour design storm event. Provide details of the stormwater mitigation system.
- The applicant shall perform deep and percolation soil testing in the vicinity of the proposed mitigation system to be witnessed by the Town Engineer. The test locations and results shall be shown on the plan. Contact the Town Engineer to schedule the testing.
- The plan shall illustrate the roof, driveway drainage and drainage pipe connections on the site plan. Include the size, slope and material.
- The plan shall illustrate and quantify the limits of disturbance. The plan shall note that disturbance limits shall be staked in the field prior to construction.

- Include erosion control measures on the plan, including, but not limited to, temporary construction access, silt fence, inlet protection, etc. Provide details.

At this time, you must submit two hard copies of revised plans addressing the above issues, this determination letter and a completed building permit application directly to the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If blasting or rock chipping is proposed, a permit pursuant to Chapter 122 is required.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.

Adam R. Kaufman, AICP
Director of Planning